

TeraPrint Produktunterlage

Gebrandete TeraPrint-Downloadunterlage

PRODUKT	Lintec
UNTERLAGE	Brandschutz-Zertifikat
TYP	fire_certificate
ORIGINALSEITEN	1
STAND	16.06.2026
DATEI	products/lintec/assets/documents/1510dd35ff8748f5d8ae3e14ec84ad0231809eec31ba65e655a225fd29d29ee0.pdf

Wichtig fuer die Produktion

Die folgenden Originalseiten bleiben in Format, Reihenfolge und Inhalt unveraendert.
Druckmass, Schnitt, Beschnitt, Sicherheitsbereiche und technische Vorlage wurden nicht veraendert.
Bei Zertifikaten, Datenblaettern und Pruefberichten bleiben Aussteller und Originalinhalte unveraendert.

TeraPrint Hinweis

Diese Datei ist lokal bei TeraPrint gespeichert und fuer den Kunden-Download vorbereitet.
Bitte bei Druckdaten immer die Massangaben und Beschnitt-/Sicherheitszonen der Originalvorlage beachten.
Bei Unsicherheit vor Bestellung oder Produktion TeraPrint kontaktieren.

Short Form Classification Report No. 20750G

PRODUCT

E-2200ZC

SPONSOR

LINTEC EUROPE BV

PRODUCT DETAILS

- Total thickness, including release liner: 0,12 mm
- Thickness of the top layer: 50 µm
- Total surface mass, including release liner: 163 g/m²
- Surface mass of the top layer: 72 g/m²
- Use amount of glue: 20 g/m²
- No use of fire retardants
- Colour (top layer): Transparent

FIELD OF APPLICATION

- Substrate: Uncoated float glass sheet of Euro class A1 with a nominal thickness of at least 6 mm
- Fixing: Directly applied onto the substrate with the self-adhesive layer
- Without joints

CLASSIFICATION

B-s1,d0

STANDARDS

Test standard: EN ISO 11925-2:2020 & EN 13823:2020

Classification standard: EN 13501-1:2018

SIGNED

APPROVED

For and on behalf of WFRGENT nv

This short form classification report has been drafted according to EGOLF agreement EGA 08rev2:2013 "Application note: clause 5.10 [5.10/1] – Types of test reports used in fire testing". Whilst the test data and classification provided within this short form report was obtained in a test conducted fully in accordance with the standards EN ISO 11925-2:2020, EN 13823:2020 and EN 13501-1:2018, the presentation of the results in this short form report may not satisfy the requirements of those standards and EN ISO/IEC 17025:2017. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted.

The full classification report No. **20750F** is available at **LINTEC EUROPE BV**.

This document is the original version of this report and is written in English. This document may be used only literally and completely for publications. For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.

The authenticity of the electronic signatures is assured by Belgium Root CA.